

ITEM 402.12

DENSE GRADED CRUSHED STONE FOR SHOULDERS

CUBIC YARD

The dense graded crushed stone for shoulders shall be placed to a width shown on the plans or as directed by the Engineer. The material is to be compacted to a depth of 4 inches level with the elevation of the finish pavement and/or top of edging or berm including under guardrail.

This material shall meet the requirements of M2.01.7 with the exception of the fine aggregate which shall consist of stone screenings and the following grading requirements:

<u>SEIVE DESIGNATION</u>	<u>% BY WEIGHT PASSING SQUARE MESH SIEVES</u>
¾ Inch	100
½ Inch	80-95
3/8 Inch	65-85
#4	35-55
#16	13-25
#50	5-15
#200	0-10

The price per cubic yard shall include full compensation for all labor, equipment, tools and other incidentals necessary for the completion of the work.