



**(To be completed by Health Division)**

Area	Number of Rooms		Residential Properties
Basement	N/A	N/A	Total # bedrooms x 110 Gallons per Day  Existing Title 5 Flow: <u>  N/A  </u>  Proposed Title 5 Flow: <u>  2,860  </u>  Net Change in Flow: <u>  2,760  </u>
1 <sup>st</sup> Floor	N/A	10	
2 <sup>nd</sup> Floor	N/A	10	
3 <sup>rd</sup> Floor	N/A	6	
Attic	N/A	N/A	
Other	N/A	N/A	
Total	N/A	N/A	
Bedrooms	N/A	26	

**Commercial Property Review  
Per 310 CMR 15.203**

Existing Use:   GAS STATION   = \_\_\_\_\_ Gallons per \_\_\_\_\_ =   300   GPD (MINIMUM)

Proposed Use:   RETAIL   = \_\_\_\_\_ Gallons per \_\_\_\_\_ =   200   GPD (MINIMUM)

Net Change in Flow =   -100   GPD

**NOTES**

A change of use has been proposed, from a fuel station to a residential building with a small-scale retail. Minimum design flow has been assumed for the fuel station and retail. Making a general balance, we have obtained an increase in flow of 2,760 gallons per day.

Date of CPH Review	Person Conducting Review	Date Sent to Sewer Dept.